



DECLARATION OF CONFORMITY

according to Directive 97/23/EC

Manufacturer, seller:

ABO valve, s.r.o.

Dalimilova 285/54, CZ-783 35 Olomouc

ID No.: 496 09 050

VAT No.: CZ-496 09 050

Product identification data:

Excentric closing valve - series 2E - 5

DN 50, 65, 80, 100 - PN 40

DN 125, 150, 200, 250, 300, 350, 400 – PN 16

Product description and identification:

Excentric butterfly valves of series 2E - 5 are used for full closing or opening of the flow of operating medium, which can be water, steam, air, natural gas, oil products, oil, petrol and oils. It is designed for the temperature range from -100°C to +600°C.

Method used for conformity assessment:

The seller confirms that the product conformity was assessed according to Directive 97/23/EC, implemented by Act 22/1997 Coll. as amended and Government Regulation 26/2003 Coll. by the type testing (model B).

This product meets the following international technical standards used in compliance assessment:

EN 12266-1,2, EN 19, EN 558, EN ISO 5211, EN 593, EN ISO 6708, EN 1092-1,2, EN 1333, API 609, API 598

This is to certify that the aforementioned pressure equipment meets all requirements of the laws and government regulations listed above.

Assessment issued by:

TÜV SÜD Czech, s.r.o.

Authorized Body No. 211

EC ID No. 1017

Olomouc, 30 September 2009

Ing. Josef KOČÍ

Executive

ABO valve s.r.o. Olomouc