

## **DECLARATION OF CONFORMITY**

according to Art. 13 of Act 22/1997 Coll. of 24 January 1997

**Manufacturer, seller:**

ABO valve, s.r.o.  
Dalimilova 285/54, 783 35 Olomouc  
ID No.: 496 09 050  
VAT No.: CZ496 09 050

**Product identification data:**

Non-flanged butterfly valves - series 900  
DN 32, 40, 50, 65, 80, 100, 125, 150, 200, - PN 16  
DN 250, 300, 350, 400, 450, 500, 600, 700, 800, 900, 1000, 1200, 1400, 1600 - PN 10 (PN 16)

**Product description and identification:**

ABO butterfly valves - series 900 are designed for full closing or opening of the flow of operating medium, which can be air, clean, polluted or hot water, hydrocarbons, chemicals and gases at temperatures from - 25°C to 130°C.

**Method used for conformity assessment:**

The seller confirms that the product conformity was assessed according to Directive 97/23/EC, implemented by Act 22/1997 Coll. as amended and Government Regulation 26/2003 Coll. by the type testing (model B).

This product meets the following harmonized Czech technical standards used in compliance assessment:

ČSN EN 12334: 2002, ČSN EN 133, ČSN EN ISO 6708, ČSN EN 558-1,2 ČSN 13 3020, ČSN 13 0010, ČSN 13 1060, ČSN 13 1061, ČSN 13 1160, ČSN 13 3060-1,2,3 ČSN EN 19, ČSN EN 10204, DIN 2501, DIN 3230

This is to certify that the aforementioned pressure equipment meets all requirements of the laws and government regulations listed above.

**Assessment issued by:**

TÜV SÜD Czech, s.r.o.  
Authorized Body No. 211  
ES IČ 101

Olomouc, 30 September 2009

Ing. Josef KOČÍ  
Executive  
ABO valve s.r.o. Olomouc